

Laboratory Report

NYE Report #: 2403953-30175

June 13, 2024

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Arlington CSD; Arlington High School

Dear Project Manager,


Enclosed is the Laboratory Analytical Report for potable water sample(s) received on June 11, 2024. New York Environmental analyzed the samples on June 11, 2024 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	07 Jun 2024
Date Received:	11 Jun 2024
Date Analyzed:	11 Jun 2024

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
240611O469	1	KIT1ICE-IM, Initial	0.001	<0.001	mg/L	
240611O470	2	KIT1F1-SK, Initial	0.001	0.003	mg/L	
240611O471	3	KIT1F2-SK, Initial	0.001	<0.001	mg/L	
240611O472	4	KITKF-PF, Initial	0.001	0.014	mg/L	H
240611O473	5	CAFECBF-BF, Initial	0.001	<0.001	mg/L	
240611O474	6	CAFECCWF-WF, Initial	0.001	<0.001	mg/L	
240611O475	7	1429ICE-IM, Initial	0.001	<0.001	mg/L	
240611O476	8	1429F1-SK, Initial	0.001	<0.001	mg/L	
240611O477	9	CBF1BF-BF, Initial	0.001	<0.001	mg/L	
240611O478	10	CBF1BH-WF, Initial	0.001	<0.001	mg/L	
240611O479	11	1CWF7-WF, Initial	0.001	0.002	mg/L	
240611O480	12	1CWF8-WF, Initial	0.001	0.002	mg/L	
240611O481	13	1CWF5-WF, Initial	0.001	<0.001	mg/L	
240611O482	14	1CWF6-WF, Initial	0.001	<0.001	mg/L	
240611O483	15	1CWF3-WF, Initial	0.001	<0.001	mg/L	
240611O484	16	1CWF4-WF, Initial	0.001	<0.001	mg/L	
240611O485	17	1CWF1-WF, Initial	0.001	0.003	mg/L	
240611O486	18	1CWF2-WF, Initial	0.001	0.002	mg/L	
240611O487	19	WAPOF-SK, Initial	0.001	<0.001	mg/L	
240611O488	20	1416F-SK, Initial	0.001	<0.001	mg/L	
240611O489	21	1456F-SK, Initial	0.001	<0.001	mg/L	
240611O490	22	1CWF9-WF, Initial	0.001	0.002	mg/L	
240611O491	23	1CWF10-WF, Initial	0.001	0.002	mg/L	
240611O492	24	1320F-SK, Initial	0.001	<0.001	mg/L	
240611O493	25	1324F-SK, Initial	0.001	0.002	mg/L	
240611O494	26	1313BRF1-SK, Initial	0.001	<0.001	mg/L	

Date Collected:	07 Jun 2024
Date Received:	11 Jun 2024
Date Analyzed:	11 Jun 2024

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
240611O495	27	1313BRF2-SK, Initial	0.001	<0.001	mg/L	
240611O496	28	1313F1-SK, Initial	0.001	0.003	mg/L	
240611O497	29	1313F2-SK, Initial	0.001	0.002	mg/L	
240611O498	30	1313F3-SK, Initial	0.001	<0.001	mg/L	
240611O499	31	1313F4-SK, Initial	0.001	<0.001	mg/L	
240611O500	32	MOKF-SK, Initial	0.001	<0.001	mg/L	
240611O501	33	LIBBF-BF, Initial	0.001	0.001	mg/L	
240611O502	34	CAFEBBCWF1-BF, Initial	0.001	<0.001	mg/L	
240611O503	35	CAFEBBCWF2-BF, Initial	0.001	<0.001	mg/L	
240611O504	36	KIT2ICE-IM, Initial	0.001	<0.001	mg/L	
240611O505	37	KIT2F2-SK, Initial	0.001	<0.001	mg/L	
240611O506	38	KIT2F7-SK, Initial	0.001	0.022	mg/L	H
240611O507	39	KIT2F8-SK, Initial	0.001	0.001	mg/L	
240611O508	40	KIT2F9-SK, Initial	0.001	0.034	mg/L	H
240611O509	41	CAFEACWF1-BF, Initial	0.001	<0.001	mg/L	
240611O510	42	CAFEACWF2-WF, Initial	0.001	<0.001	mg/L	
240611O511	43	1CWF17-WF, Initial	0.001	0.004	mg/L	
240611O512	44	1CWF15-WF, Initial	0.001	<0.001	mg/L	
240611O513	45	1CWF16-WF, Initial	0.001	<0.001	mg/L	
240611O514	46	1CWF13-WF, Initial	0.001	<0.001	mg/L	
240611O515	47	1CWF14-WF, Initial	0.001	<0.001	mg/L	
240611O516	48	SAPOF-SK, Initial	0.001	0.005	mg/L	
240611O517	49	2CWF11-WF, Initial	0.001	<0.001	mg/L	
240611O518	50	2CWF12-WF, Initial	0.001	<0.001	mg/L	
240611O519	51	2CWF10-WF, Initial	0.001	0.002	mg/L	
240611O520	52	1CWF12-WF, Initial	0.001	0.003	mg/L	
240611O521	53	EAPOF-SK, Initial	0.001	0.002	mg/L	



Date Collected:	07 Jun 2024
Date Received:	11 Jun 2024
Date Analyzed:	11 Jun 2024

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
240611O522	54	1116F1-SK, Initial	0.001	0.001	mg/L	
240611O523	55	1116F2-SK, Initial	0.001	<0.001	mg/L	
240611O524	56	1119F1-SK, Initial	0.001	0.002	mg/L	
240611O525	57	1119F2-SK, Initial	0.001	0.005	mg/L	
240611O526	58	1119F3-SK, Initial	0.001	0.002	mg/L	
240611O527	59	1119F4-SK, Initial	0.001	0.002	mg/L	
240611O528	60	1119F5-SK, Initial	0.001	0.004	mg/L	
240611O529	61	1119F6-SK, Initial	0.001	0.003	mg/L	
240611O530	62	1119F4A-SK, Initial	0.001	<0.001	mg/L	
240611O531	63	1CWF11-WF, Initial	0.001	0.003	mg/L	
240611O532	64	1BH-WF, Initial	0.001	0.019	mg/L	H
240611O533	65	2112F-SK, Initial	0.001	0.002	mg/L	
240611O534	66	2112SPY-SPY, Initial	0.001	0.002	mg/L	
240611O535	67	2126F-SK, Initial	0.001	0.001	mg/L	
240611O536	68	1232F1-SK, Initial	0.001	0.003	mg/L	
240611O537	69	1232ICE-IM, Initial	0.001	<0.001	mg/L	
240611O538	70	LR2F-SP, Initial	0.001	<0.001	mg/L	
240611O539	71	1CWF18-WF, Initial	0.001	0.002	mg/L	
240611O540	72	2CWF5-WF, Initial	0.001	0.002	mg/L	
240611O541	73	2CWF6-WF, Initial	0.001	0.003	mg/L	
240611O542	74	2CWF3-WF, Initial	0.001	0.001	mg/L	
240611O543	75	2CWF4-WF, Initial	0.001	0.003	mg/L	
240611O544	76	2323F-SK, Initial	0.001	0.003	mg/L	
240611O545	77	2CWF1-WF, Initial	0.001	0.002	mg/L	
240611O546	78	2CWF2-WF, Initial	0.001	0.002	mg/L	
240611O547	79	2331F-SK, Initial	0.001	0.009	mg/L	H
240611O548	80	2CWF7-WF, Initial	0.001	0.001	mg/L	



Date Collected:	07 Jun 2024
Date Received:	11 Jun 2024
Date Analyzed:	11 Jun 2024

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

<u>Lab ID</u>	<u>CID</u>	<u>Sample Location/Description</u>	<u>LOQ</u>	<u>Result</u>	<u>Units</u>	<u>Flag</u>
240611O549	81	2CWF8-WF, Initial	0.001	0.002	mg/L	
240611O550	82	1433F-SK, Initial	0.001	<0.001	mg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

H: Sample result exceeds applicable regulatory limit.