

Laboratory Report

NYE Report #: 2404051-30216

June 15, 2024

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Arlington CSD; Beekman Elementary School

Dear Project Manager,


Enclosed is the Laboratory Analytical Report for potable water sample(s) received on June 12, 2024. New York Environmental analyzed the samples on June 13, 2024 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	12 Jun 2024
Date Received:	12 Jun 2024
Date Analyzed:	13 Jun 2024

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
240613M004	1	Kitchen Island Prep-SK, Initial	0.001	0.004	mg/L	
240613M005	2	Custodian Office-SK, Initial	0.001	0.001	mg/L	
240613M006	3	Room 9-SK, Initial	0.001	0.001	mg/L	
240613M007	4	Room 9-WF, Initial	0.001	0.004	mg/L	
240613M008	5	Room 11-SK, Initial	0.001	0.003	mg/L	
240613M009	6	Room 11-WF, Initial	0.001	0.017	mg/L	H
240613M010	7	Room 13-SK, Initial	0.001	0.002	mg/L	
240613M011	8	Room 13-WF, Initial	0.001	0.006	mg/L	H
240613M012	9	Room 17-SK, Initial	0.001	<0.001	mg/L	
240613M013	10	Room 19-SK, Initial	0.001	<0.001	mg/L	
240613M014	11	Room 20-SK, Initial	0.001	<0.001	mg/L	
240613M015	12	Room 18-SK, Initial	0.001	<0.001	mg/L	
240613M016	13	Gym Water Fountain-WF, Initial	0.001	0.002	mg/L	
240613M017	14	Hallway into modular-SK, Initial	0.001	<0.001	mg/L	
240613M018	15	Room 14-SK, Initial	0.001	0.003	mg/L	
240613M019	16	Room 14-WF, Initial	0.001	0.005	mg/L	
240613M020	17	Room 12-SK, Initial	0.001	0.002	mg/L	
240613M021	18	Room 12-WF, Initial	0.001	0.008	mg/L	H
240613M022	19	Room 10-SK, Initial	0.001	0.003	mg/L	
240613M023	20	Room 10-WF, Initial	0.001	0.007	mg/L	H
240613M024	21	Hall by Room 10-BF, Initial	0.001	<0.001	mg/L	
240613M025	22	Hall by Room 10-WF, Initial	0.001	<0.001	mg/L	
240613M026	23	Faculty Room-SK, Initial	0.001	<0.001	mg/L	
240613M027	24	Health Office-SK, Initial	0.001	0.003	mg/L	
240613M028	25	Health Office Bathroom-SK, Initial	0.001	0.003	mg/L	
240613M029	26	Water Fountain at entrance to Media Center-SK, Initial	0.001	<0.001	mg/L	

Date Collected:	12 Jun 2024
Date Received:	12 Jun 2024
Date Analyzed:	13 Jun 2024

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
240613M030	27	Boy's Bathroom by Room 32-SK, Initial	0.001	0.002	mg/L	
240613M031	28	Girl's Bathroom by Room 32-SK, Initial	0.001	0.003	mg/L	
240613M032	29	Hallway by Room 32-SK, Initial	0.001	<0.001	mg/L	
240613M033	30	Room 32-SK, Initial	0.001	0.003	mg/L	
240613M034	31	Hallway by Room 31-SK, Initial	0.001	0.006	mg/L	H
240613M035	32	Hallway by Room 30-SK, Initial	0.001	0.002	mg/L	
240613M036	33	Room 28-SK, Initial	0.001	0.005	mg/L	
240613M037	34	Room 27-SK, Initial	0.001	<0.001	mg/L	
240613M038	35	Sink outside room 25-SK, Initial	0.001	0.001	mg/L	
240613M039	36	Sink outside room 23-SK, Initial	0.001	0.002	mg/L	
240613M040	37	Sink Outside Boy's Room Near Room 23-SK, Initial	0.001	0.002	mg/L	
240613M041	38	Sink Outside Girl's Room Near Room 23-SK, Initial	0.001	0.001	mg/L	
240613M042	39	Room 37A-SK, Initial	0.001	0.010	mg/L	H
240613M043	40	Library Office-SK, Initial	0.001	0.009	mg/L	H
240613M044	41	Room 6-SK, Initial	0.001	0.004	mg/L	
240613M045	42	Room 6-WF, Initial	0.001	0.001	mg/L	
240613M046	43	Room 4-SK, Initial	0.001	0.007	mg/L	H
240613M047	44	Room 4-WF, Initial	0.001	0.003	mg/L	
240613M048	45	Room 2-SK, Initial	0.001	0.006	mg/L	H
240613M049	46	Room 2-WF, Initial	0.001	0.001	mg/L	
240613M050	47	Room 3-SK, Initial	0.001	0.004	mg/L	
240613M051	48	Room 3-WF, Initial	0.001	<0.001	mg/L	
240613M052	49	Room 1-SK, Initial	0.001	<0.001	mg/L	
240613M053	50	Room 1-WF, Initial	0.001	0.001	mg/L	
240613M054	51	Room 5-SK, Initial	0.001	0.002	mg/L	
240613M055	52	Room 5-WF, Initial	0.001	0.001	mg/L	
240613M056	53	Room 7-Art Room-SK, Initial	0.001	0.001	mg/L	



Date Collected:	12 Jun 2024
Date Received:	12 Jun 2024
Date Analyzed:	13 Jun 2024

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
--------	-----	-----------------------------	-----	--------	-------	------

Comment:

CID: Client ID LOQ: Limit of Quantitation

H: Sample result exceeds applicable regulatory limit.

