

Laboratory Report

NYE Report #: 2403955-30180

June 13, 2024

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Arlington CSD; Central Admin Office

Dear Project Manager,

Enclosed is the Laboratory Analytical Report for potable water sample(s) received on June 11, 2024. New York Environmental analyzed the samples on June 12, 2024 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	11 Jun 2024
Date Received:	11 Jun 2024
Date Analyzed:	12 Jun 2024

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
240611R011	1	Room 2-SK, Initial	0.001	<0.001	mg/L	
240611R012	2	Room 1-SK, Initial	0.001	<0.001	mg/L	
240611R013	3	Room 1-WF, Initial	0.001	0.001	mg/L	
240611R014	4	Room 23B-SK, Initial	0.001	0.011	mg/L	H
240611R015	5	Hallway Water Fountain-WF, Initial	0.001	<0.001	mg/L	
240611R016	6	Room 20A-SK, Initial	0.001	<0.001	mg/L	
240611R017	7	Room 17-SK, Initial	0.001	<0.001	mg/L	
240611R018	8	Room 16-SK, Initial	0.001	<0.001	mg/L	
240611R019	9	Room 15-SK, Initial	0.001	0.073	mg/L	E,H
240611R020	10	Room 14-SK, Initial	0.001	<0.001	mg/L	
240611R021	11	Room 12B-SK, Initial	0.001	0.001	mg/L	
240611R022	12	Room 11B-SK, Initial	0.001	0.008	mg/L	H
240611R023	13	Room 27B-SK, Initial	0.001	0.001	mg/L	
240611R024	14	Room 29A-SK, Initial	0.001	<0.001	mg/L	
240611R025	15	Room 29C-SK, Initial	0.001	0.002	mg/L	
240611R026	16	Room 30C-SK, Initial	0.001	0.006	mg/L	H
240611R027	17	Room 31C-SK, Initial	0.001	0.005	mg/L	
240611R028	18	Room 32-SK, Initial	0.001	0.001	mg/L	
240611R029	19	Room 33-SK, Initial	0.001	0.001	mg/L	
240611R030	20	Room 34-SK, Initial	0.001	<0.001	mg/L	
240611R031	21	Room 35C-SK, Initial	0.001	0.007	mg/L	H
240611R032	22	Room 36B-SK, Initial	0.001	<0.001	mg/L	
240611R033	23	Room 37B-SK, Initial	0.001	<0.001	mg/L	
240611R034	24	Hallway Right Fountain-WF, Initial	0.001	<0.001	mg/L	
240611R035	25	Hallway Left Fountain-WF, Initial	0.001	<0.001	mg/L	
240611R036	26	Room 38-SK, Initial	0.001	<0.001	mg/L	

Date Collected:	11 Jun 2024
Date Received:	11 Jun 2024
Date Analyzed:	12 Jun 2024

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

<u>Lab ID</u>	<u>CID</u>	<u>Sample Location/Description</u>	<u>LOQ</u>	<u>Result</u>	<u>Units</u>	<u>Flag</u>
240611R037	27	Room 38-SPY, Initial	0.001	<0.001	mg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

E: Sample result exceeds instrument calibration, value is estimated.

H: Sample result exceeds applicable regulatory limit.