

Laboratory Report

NYE Report #: 2404036-30204

June 15, 2024

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Arlington Csd; Noxon Road School

Dear Project Manager,

Enclosed is the Laboratory Analytical Report for potable water sample(s) received on June 12, 2024. New York Environmental analyzed the samples on June 13, 2024 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	12 Jun 2024
Date Received:	12 Jun 2024
Date Analyzed:	13 Jun 2024

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
240612P053	1	Kitchen 3 Deep Basins-SK, Initial	0.001	<0.001	mg/L	
240612P054	2	Cafeteria-BF, Initial	0.001	<0.001	mg/L	
240612P055	3	Cafeteria-WF, Initial	0.001	<0.001	mg/L	
240612P056	4	Gym Hall by Girl's Locker Room-WF, Initial	0.001	0.003	mg/L	
240612P057	5	Hall by Cafe/Gym-WF, Initial	0.001	0.004	mg/L	
240612P058	6	Health Office-SK, Initial	0.001	0.003	mg/L	
240612P059	7	Health Office Bathroom-SK, Initial	0.001	0.004	mg/L	
240612P060	8	Main Office-SK, Initial	0.001	0.002	mg/L	
240612P061	9	Room 103-SK, Initial	0.001	0.002	mg/L	
240612P062	10	Room 103-WF, Initial	0.001	0.002	mg/L	
240612P063	11	Room 105-SK, Initial	0.001	0.002	mg/L	
240612P064	12	Room 105-WF, Initial	0.001	0.005	mg/L	
240612P065	13	Room 106-SK, Initial	0.001	0.002	mg/L	
240612P066	14	Room 106-WF, Initial	0.001	0.002	mg/L	
240612P067	15	Room 107-SK, Initial	0.001	0.002	mg/L	
240612P068	16	Room 104-SK, Initial	0.001	0.002	mg/L	
240612P069	17	Room 104-WF, Initial	0.001	0.006	mg/L	H
240612P070	18	Faculty Room 108-SK, Initial	0.001	0.002	mg/L	
240612P071	19	Room 102-SK, Initial	0.001	0.002	mg/L	
240612P072	20	Room 102-WF, Initial	0.001	0.002	mg/L	
240612P073	21	Room 112 Library-SK, Initial	0.001	0.003	mg/L	
240612P074	22	Room 109-SK, Initial	0.001	<0.001	mg/L	
240612P075	23	Room 109-WF, Initial	0.001	0.007	mg/L	H
240612P076	24	Room 110-SK, Initial	0.001	0.003	mg/L	
240612P077	25	Room 110-WF, Initial	0.001	0.002	mg/L	
240612P078	26	Room 101-SK, Initial	0.001	0.003	mg/L	



Date Collected:	12 Jun 2024
Date Received:	12 Jun 2024
Date Analyzed:	13 Jun 2024

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
240612P079	27	Room 101-WF, Initial	0.001	0.003	mg/L	
240612P080	28	Room 201-SK, Initial	0.001	0.002	mg/L	
240612P081	29	Room 201-WF, Initial	0.001	0.002	mg/L	
240612P082	30	Room 202-SK, Initial	0.001	0.002	mg/L	
240612P083	31	Room 202-WF, Initial	0.001	0.002	mg/L	
240612P084	32	Room 203-SK, Initial	0.001	0.001	mg/L	
240612P085	33	Room 203-WF, Initial	0.001	0.003	mg/L	
240612P086	34	Room 204-SK, Initial	0.001	0.003	mg/L	
240612P087	35	Room 204-WF, Initial	0.001	0.003	mg/L	
240612P088	36	Room 205-SK, Initial	0.001	0.002	mg/L	
240612P089	37	Room 205-WF, Initial	0.001	0.002	mg/L	
240612P090	38	Room 206-SK, Initial	0.001	0.002	mg/L	
240612P091	39	Room 206-WF, Initial	0.001	0.002	mg/L	
240612P092	40	Hall by Room 208-WF, Initial	0.001	0.003	mg/L	
240612P093	41	Room 215-SK, Initial	0.001	0.006	mg/L	H
240612P094	42	Room 207-SK, Initial	0.001	0.002	mg/L	
240612P095	43	Room 207-WF, Initial	0.001	0.003	mg/L	
240612P096	44	Room 208-SK, Initial	0.001	0.001	mg/L	
240612P097	45	Room 208-WF, Initial	0.001	0.001	mg/L	
240612P098	46	Room 209-SK, Initial	0.001	0.002	mg/L	
240612P099	47	Room 209-WF, Initial	0.001	0.002	mg/L	
240612P100	48	Room 210-SK, Initial	0.001	<0.001	mg/L	
240612P101	49	Room 210-WF, Initial	0.001	0.001	mg/L	
240612P102	50	Room 211-SK, Initial	0.001	0.003	mg/L	
240612P103	51	Room 211-WF, Initial	0.001	<0.001	mg/L	
240612P104	52	Room 212-SK, Initial	0.001	0.003	mg/L	
240612P105	53	Room 212-WF, Initial	0.001	0.001	mg/L	



Date Collected:	12 Jun 2024
Date Received:	12 Jun 2024
Date Analyzed:	13 Jun 2024

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

<u>Lab ID</u>	<u>CID</u>	<u>Sample Location/Description</u>	<u>LOQ</u>	<u>Result</u>	<u>Units</u>	<u>Flag</u>
240612P106	54	Room 214-WF, Initial	0.001	0.003	mg/L	
240612P107	55	Room 214-WF, Initial	0.001	0.008	mg/L	H

Comment:

CID: Client ID LOQ: Limit of Quantitation

H: Sample result exceeds applicable regulatory limit.