

Laboratory Report

NYE Report #: 2403839-30088

June 11, 2024

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Traver Road Primary School; 801 Traver Road Pleasant Valley, NY

Dear Project Manager,

Enclosed is the Laboratory Analytical Report for potable water sample(s) received on June 07, 2024. New York Environmental analyzed the samples on June 10, 2024 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	06 Jun 2024
Date Received:	07 Jun 2024
Date Analyzed:	10 Jun 2024

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
240607L014	1	PF	0.001	<0.001	mg/L	
240607L015	2	JOF1	0.001	<0.001	mg/L	
240607L016	3	HOF2	0.001	0.001	mg/L	
240607L017	4	HOFBRF	0.001	<0.001	mg/L	
240607L018	5	5F	0.001	0.001	mg/L	
240607L019	6	8F	0.001	0.001	mg/L	
240607L020	7	9F	0.001	<0.001	mg/L	
240607L021	8	10F	0.001	<0.001	mg/L	
240607L022	9	12F	0.001	<0.001	mg/L	
240607L023	10	13F	0.001	<0.001	mg/L	
240607L024	11	14F	0.001	<0.001	mg/L	
240607L025	12	CRF	0.001	0.002	mg/L	
240607L026	13	KIT1 Island	0.001	<0.001	mg/L	
240607L027	14	LIBOF	0.001	0.072	mg/L	E,H

Comment:

CID: Client ID LOQ: Limit of Quantitation

E: Sample result exceeds instrument calibration, value is estimated.

H: Sample result exceeds applicable regulatory limit.

