

Laboratory Report

NYE Report #: 2403961-30183

June 13, 2024

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Arlington CSD; Union Vale Middle School

Dear Project Manager,

Enclosed is the Laboratory Analytical Report for potable water sample(s) received on June 11, 2024. New York Environmental analyzed the samples on June 12, 2024 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	11 Jun 2024
Date Received:	11 Jun 2024
Date Analyzed:	12 Jun 2024

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
240611R090	1	Kitchen Prep by Ice Machine-SPY, Initial	0.001	0.005	mg/L	
240611R091	2	Kitchen Ice Machine-IM, Initial	0.001	<0.001	mg/L	
240611R092	3	Kitchen Island Prep-PF, Initial	0.001	0.003	mg/L	
240611R093	4	Kitchen Pot Filler Spray-SPY, Initial	0.001	0.004	mg/L	
240611R094	5	Kitchen Pot Filler-PF, Initial	0.001	0.002	mg/L	
240611R095	6	Faculty Room-SK, Initial	0.001	<0.001	mg/L	
240611R096	7	Elevator Hallway-WF, Initial	0.001	<0.001	mg/L	
240611R097	8	Elevator Hallway-WF, Initial	0.001	<0.001	mg/L	
240611R098	9	Gym Hall Left-WF, Initial	0.001	<0.001	mg/L	
240611R099	10	Room 123 Sink 1-SK, Initial	0.001	<0.001	mg/L	
240611R100	11	Room 123 Sink 4-SK, Initial	0.001	0.005	mg/L	
240611R101	12	Home And Careers Hallway-WF, Initial	0.001	<0.001	mg/L	
240611R102	13	Home And Careers Hallway-WF, Initial	0.001	<0.001	mg/L	
240611R103	14	By Art Room 115-WF, Initial	0.001	<0.001	mg/L	
240611R104	15	By Art Room 115-WF, Initial	0.001	<0.001	mg/L	
240611R105	16	Room 113-SK, Initial	0.001	0.004	mg/L	
240611R106	17	Main Office Lunch Room-SK, Initial	0.001	<0.001	mg/L	
240611R107	18	Office/Cafe Hallway-WF, Initial	0.001	<0.001	mg/L	
240611R108	19	Office/Cafe Hallway-BF, Initial	0.001	<0.001	mg/L	
240611R109	20	Heath Office-SK, Initial	0.001	0.002	mg/L	
240611R110	21	Health Office Exam Room-SK, Initial	0.001	0.003	mg/L	
240611R111	22	Health Office Isolation Room-SK, Initial	0.001	0.002	mg/L	
240611R112	23	Health Office Bathroom-SK, Initial	0.001	<0.001	mg/L	
240611R113	24	Library Office-SK, Initial	0.001	0.002	mg/L	
240611R114	25	Hall by Room 215 Left-BF, Initial	0.001	<0.001	mg/L	
240611R115	26	Hall by Room 215 Right-WF, Initial	0.001	<0.001	mg/L	



Date Collected:	11 Jun 2024
Date Received:	11 Jun 2024
Date Analyzed:	12 Jun 2024

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

<u>Lab ID</u>	<u>CID</u>	<u>Sample Location/Description</u>	<u>LOQ</u>	<u>Result</u>	<u>Units</u>	<u>Flag</u>
240611R116	27	Hall by Room 225 Left-WF, Initial	0.001	0.002	mg/L	
240611R117	28	Hall by Room 225 Right-WF, Initial	0.001	0.003	mg/L	
240611R118	29	Faculty Room-SK, Initial	0.001	0.003	mg/L	
240611R119	30	OT/PT Office-SK, Initial	0.001	0.004	mg/L	
240611R120	31	Hall by Elevator Left-WF, Initial	0.001	0.001	mg/L	
240611R121	32	Hall by Elevator Right-WF, Initial	0.001	0.002	mg/L	
240611R122	33	Room 123 Sink 2-SK, Initial	0.001	0.002	mg/L	
240611R123	34	Room 123 Sink 3-SK, Initial	0.001	0.002	mg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation