

Laboratory Report

NYE Report #: 2403962-30184

June 13, 2024

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Arlington CSD; Vail Farm Elementary School

Dear Project Manager,

Enclosed is the Laboratory Analytical Report for potable water sample(s) received on June 11, 2024. New York Environmental analyzed the samples on June 12, 2024 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	11 Jun 2024
Date Received:	11 Jun 2024
Date Analyzed:	12 Jun 2024

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
240611R124	1	Kitchen Potfiller-PF, Initial	0.001	0.007	mg/L	H
240611R125	2	Kitchen Potfiller-SPY, Initial	0.001	0.004	mg/L	
240611R126	3	Kitchen Prep by Dishwash Station-SK, Initial	0.001	0.003	mg/L	
240611R127	4	Kitchen Prep by Stove-SK, Initial	0.001	0.002	mg/L	
240611R128	5	Kitchen Prep by Serving Line-SK, Initial	0.001	0.001	mg/L	
240611R129	6	Hall by Speech Office Left-WF, Initial	0.001	<0.001	mg/L	
240611R130	7	Hall by Speech Office Right-WF, Initial	0.001	<0.001	mg/L	
240611R131	8	Speech Office-SK, Initial	0.001	0.002	mg/L	
240611R132	9	Room 30-SK, Initial	0.001	<0.001	mg/L	
240611R133	10	Library Office-SK, Initial	0.001	<0.001	mg/L	
240611R134	11	Room 31-SK, Initial	0.001	<0.001	mg/L	
240611R135	12	Health Office-SK, Initial	0.001	0.001	mg/L	
240611R136	13	Health Office Exam Room-SK, Initial	0.001	<0.001	mg/L	
240611R137	14	Health Office Bathroom-SK, Initial	0.001	0.001	mg/L	
240611R138	15	Main Office Work Room-SK, Initial	0.001	<0.001	mg/L	
240611R139	16	Hall by Main Office Left-WF, Initial	0.001	<0.001	mg/L	
240611R140	17	Hall by Main Office Right-WF, Initial	0.001	<0.001	mg/L	
240611R141	18	Room 1-SK, Initial	0.001	<0.001	mg/L	
240611R142	19	Room 3-SK, Initial	0.001	<0.001	mg/L	
240611R143	20	Room 4-SK, Initial	0.001	<0.001	mg/L	
240611R144	21	Room 5-SK, Initial	0.001	<0.001	mg/L	
240611R145	22	Room 6-SK, Initial	0.001	<0.001	mg/L	
240611R146	23	Room 7-SK, Initial	0.001	0.001	mg/L	
240611R147	24	Room 8-SK, Initial	0.001	<0.001	mg/L	
240611R148	25	Room 9-SK, Initial	0.001	<0.001	mg/L	
240611R149	26	Room 10-SK, Initial	0.001	<0.001	mg/L	



Date Collected:	11 Jun 2024
Date Received:	11 Jun 2024
Date Analyzed:	12 Jun 2024

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
240611R150	27	Room 11-SK, Initial	0.001	<0.001	mg/L	
240611R151	28	Hall by Room 11 Left-WF, Initial	0.001	<0.001	mg/L	
240611R152	29	Hall by Room 11 Right-WF, Initial	0.001	<0.001	mg/L	
240611R153	30	Room 12-SK, Initial	0.001	0.001	mg/L	
240611R154	31	Room 13-SK, Initial	0.001	<0.001	mg/L	
240611R155	32	Room 15-SK, Initial	0.001	0.001	mg/L	
240611R156	33	Room 17-SK, Initial	0.001	0.001	mg/L	
240611R157	34	Room 18-SK, Initial	0.001	0.003	mg/L	
240611R158	35	Hall by Room 18 Left-WF, Initial	0.001	<0.001	mg/L	
240611R159	36	Hall by Room 18 Right-WF, Initial	0.001	<0.001	mg/L	
240611R160	37	Room 16-SK, Initial	0.001	<0.001	mg/L	
240611R161	38	Room 14-SK, Initial	0.001	0.002	mg/L	
240611R162	39	Room 32-SK, Initial	0.001	0.001	mg/L	
240611R163	40	Room 33-SK, Initial	0.001	0.001	mg/L	
240611R164	41	Room 34-SK, Initial	0.001	<0.001	mg/L	
240611R165	42	Room 36-SK, Initial	0.001	0.001	mg/L	
240611R166	43	Room 37-SK, Initial	0.001	<0.001	mg/L	
240611R167	44	Room 38-SK, Initial	0.001	0.002	mg/L	
240611R168	45	Room 39-SK, Initial	0.001	<0.001	mg/L	
240611R169	46	Room 40-SK, Initial	0.001	<0.001	mg/L	
240611R170	47	Room 41-SK, Initial	0.001	<0.001	mg/L	
240611R171	48	Room 42-SK, Initial	0.001	<0.001	mg/L	
240611R172	49	Room 43-SK, Initial	0.001	<0.001	mg/L	
240611R173	50	Room 44-SK, Initial	0.001	<0.001	mg/L	
240611R174	51	Room 45-SK, Initial	0.001	0.001	mg/L	
240611R175	52	Room 46-SK, Initial	0.001	0.001	mg/L	
240611R176	53	Room 47-SK, Initial	0.001	0.001	mg/L	



Date Collected:	11 Jun 2024
Date Received:	11 Jun 2024
Date Analyzed:	12 Jun 2024

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
240611R177	54	Room 19-SK, Initial	0.001	<0.001	mg/L	
240611R178	55	Room 20-SK, Initial	0.001	0.002	mg/L	
240611R179	56	Room 21-SK, Initial	0.001	0.002	mg/L	
240611R180	57	Room 23-SK, Initial	0.001	0.001	mg/L	
240611R181	58	Room 22-SK, Initial	0.001	<0.001	mg/L	
240611R182	59	Room 24-SK, Initial	0.001	0.002	mg/L	
240611R183	60	Room 25-SK, Initial	0.001	0.001	mg/L	
240611R184	61	Room 26-SK, Initial	0.001	<0.001	mg/L	
240611R185	62	Hall by Room 26 Left-WF, Initial	0.001	<0.001	mg/L	
240611R186	63	Hall by Room 26 Right-WF, Initial	0.001	<0.001	mg/L	
240611R187	64	Faculty Room-SK, Initial	0.001	<0.001	mg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

H: Sample result exceeds applicable regulatory limit.